

Certificate of Analysis

Sample ID: AGC3527-01
 Sampled By: Rafael Farfan
 Sample Description: 18 Secondo Way // 230329_36-01

Sample Date - Time: 03/29/2023 - 13:00
 Matrix: Drinking Water
 Sample Type: Grab

BSK Associates Laboratory Fresno
Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>EDB and DBCP by GC-ECD</u>									
Ethylene Dibromide (EDB)	EPA 504.1	ND	0.020	ug/L	1	AGC1912	03/31/23	04/01/23	
Dibromochloropropane (DBCP)	EPA 504.1	ND	0.010	ug/L	1	AGC1912	03/31/23	04/01/23	
Surrogate: 1-Br-2-Nitrobenzene	EPA 504.1	98 %	Acceptable range: 70-130 %						
<u>Organohalide Pesticides and PCBs by GC-ECD</u>									
Aldrin	EPA 505	ND	0.075	ug/L	1	AGC1912	03/31/23	04/01/23	
Chlordane (Technical)	EPA 505	ND	0.10	ug/L	1	AGC1912	03/31/23	04/01/23	
Dieldrin	EPA 505	ND	0.020	ug/L	1	AGC1912	03/31/23	04/01/23	
Endrin	EPA 505	ND	0.10	ug/L	1	AGC1912	03/31/23	04/01/23	
Heptachlor	EPA 505	ND	0.010	ug/L	1	AGC1912	03/31/23	04/01/23	
Heptachlor Epoxide	EPA 505	ND	0.010	ug/L	1	AGC1912	03/31/23	04/01/23	
Hexachlorobenzene	EPA 505	ND	0.50	ug/L	1	AGC1912	03/31/23	04/01/23	
Hexachlorocyclopentadiene	EPA 505	ND	1.0	ug/L	1	AGC1912	03/31/23	04/01/23	
Lindane	EPA 505	ND	0.20	ug/L	1	AGC1912	03/31/23	04/01/23	
Methoxychlor	EPA 505	ND	10	ug/L	1	AGC1912	03/31/23	04/01/23	
PCB Aroclor Screen	EPA 505	ND	0.50	ug/L	1	AGC1912	03/31/23	04/01/23	
Toxaphene	EPA 505	ND	1.0	ug/L	1	AGC1912	03/31/23	04/01/23	
Surrogate: 1-Br-2-Nitrobenzene	EPA 505	98 %	Acceptable range: 70-130 %						
<u>Chlorinated Acid Herbicides by GC-ECD</u>									
2,4,5-T	EPA 515.4	ND	1.0	ug/L	1	AGD0020	04/03/23	04/05/23	
2,4,5-TP (Silvex)	EPA 515.4	ND	1.0	ug/L	1	AGD0020	04/03/23	04/05/23	
2,4-D	EPA 515.4	ND	10	ug/L	1	AGD0020	04/03/23	04/05/23	
Bentazon	EPA 515.4	ND	2.0	ug/L	1	AGD0020	04/03/23	04/05/23	
Dalapon	EPA 515.4	ND	10	ug/L	1	AGD0020	04/03/23	04/05/23	
Dicamba	EPA 515.4	ND	1.5	ug/L	1	AGD0020	04/03/23	04/05/23	
Dinoseb	EPA 515.4	ND	2.0	ug/L	1	AGD0020	04/03/23	04/05/23	
Pentachlorophenol	EPA 515.4	ND	0.20	ug/L	1	AGD0020	04/03/23	04/05/23	
Picloram	EPA 515.4	ND	1.0	ug/L	1	AGD0020	04/03/23	04/05/23	
Surrogate: DCPAA	EPA 515.4	103 %	Acceptable range: 70-130 %						
<u>Volatile Organics (SDWA Regulated) by GC-MS</u>									
1,1,1-Trichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1,2,2-Tetrachloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1,2-Trichloro-1,2,2-trifluoroethane	EPA 524.2	ND	10	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1,2-Trichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1-Dichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2,4-Trichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2-Dichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2-Dichloropropane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,4-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AGC3527 FINAL 04052023 1826



AGC3527

General EDT
Sunny Mesa WS

Certificate of Analysis

Sample ID: AGC3527-01
 Sampled By: Rafael Farfan
 Sample Description: 18 Secondo Way // 230329_36-01

Sample Date - Time: 03/29/2023 - 13:00
 Matrix: Drinking Water
 Sample Type: Grab

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Volatile Organics (SDWA Regulated) by GC-MS									
Benzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Carbon Tetrachloride	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Chlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
cis-1,2-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
cis-1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Dichloromethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Ethylbenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
m,p-Xylenes	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Methyl-t-butyl ether	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
o-Xylene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Styrene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Tetrachloroethene (PCE)	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Toluene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
trans-1,2-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
trans-1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Trichloroethene (TCE)	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Trichlorofluoromethane	EPA 524.2	ND	5.0	ug/L	1	AGD0112	04/04/23	04/04/23	
Vinyl Chloride	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Total 1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Total Xylenes	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Surrogate: 1,2-Dichlorobenzene-d4	EPA 524.2	101 %							Acceptable range: 70-130 %
Surrogate: Bromofluorobenzene	EPA 524.2	100 %							Acceptable range: 70-130 %
Semi-Volatile Organics by GC-MS									
Alachlor	EPA 525.3	ND	1.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Atrazine	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Benzo(a)pyrene	EPA 525.3	ND	0.10	ug/L	1	AGC1904	03/30/23	04/03/23	
Bis(2-ethylhexyl) adipate	EPA 525.3	ND	3.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Bis(2-ethylhexyl) phthalate	EPA 525.3	ND	3.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Bromacil	EPA 525.3	ND	10	ug/L	1	AGC1904	03/30/23	04/03/23	
Butachlor	EPA 525.3	ND	0.38	ug/L	1	AGC1904	03/30/23	04/03/23	
Diazinon	EPA 525.3	ND	0.25	ug/L	1	AGC1904	03/30/23	04/03/23	
Dimethoate	EPA 525.3	ND	10	ug/L	1	AGC1904	03/30/23	04/03/23	
Metolachlor	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Metribuzin	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Molinate	EPA 525.3	ND	2.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Propachlor	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Simazine	EPA 525.3	ND	1.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Thiobencarb	EPA 525.3	ND	1.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Surrogate: 1,3-Dimethyl-2-nitrobenzene	EPA 525.3	91 %							Acceptable range: 70-130 %
Surrogate: Benzo(a)pyrene-d12	EPA 525.3	95 %							Acceptable range: 70-130 %
Surrogate: Triphenyl Phosphate	EPA 525.3	115 %							Acceptable range: 70-130 %

Carbamates by HPLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AGC3527 FINAL 04052023 1826



AGC3527

General EDT
Sunny Mesa WS

Certificate of Analysis

Sample ID: AGC3527-01
 Sampled By: Rafael Farfan
 Sample Description: 18 Secondo Way // 230329_36-01

Sample Date - Time: 03/29/2023 - 13:00
 Matrix: Drinking Water
 Sample Type: Grab

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>Carbamates by HPLC</u>									
3-Hydroxycarbofuran	EPA 531.1	ND	3.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Aldicarb	EPA 531.1	ND	3.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Aldicarb Sulfone	EPA 531.1	ND	2.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Aldicarb Sulfoxide	EPA 531.1	ND	3.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Carbaryl	EPA 531.1	ND	5.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Carbofuran	EPA 531.1	ND	5.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Methomyl	EPA 531.1	ND	2.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Oxamyl	EPA 531.1	ND	20	ug/L	1	AGD0090	04/04/23	04/05/23	
<u>Glyphosate by HPLC</u>									
Glyphosate	EPA 547	ND	25	ug/L	1	AGC1851	03/30/23	03/30/23	
Surrogate: AMPA	EPA 547	97 %	<i>Acceptable range: 70-130 %</i>						
<u>Endothall by GC-MS</u>									
Endothall	EPA 548.1	ND	45	ug/L	1	AGC1969	03/31/23	04/03/23	
<u>Diquat by HPLC</u>									
Diquat	EPA 549.2	ND	4.0	ug/L	1	AGD0010	04/02/23	04/04/23	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



AGC3527

General EDT
Sunny Mesa WS

Certificate of Analysis

Sample ID: AGC3527-02
 Sampled By: Rafael Farfan
 Sample Description: 19 Bay Farms Rd // 230329_36-02


Sample Date - Time: 03/29/2023 - 13:30
 Matrix: Drinking Water
 Sample Type: Grab

BSK Associates Laboratory Fresno
Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
EDB and DBCP by GC-ECD									
Ethylene Dibromide (EDB)	EPA 504.1	ND	0.020	ug/L	1	AGC1912	03/31/23	04/01/23	
Dibromochloropropane (DBCP)	EPA 504.1	ND	0.010	ug/L	1	AGC1912	03/31/23	04/01/23	
Surrogate: 1-Br-2-Nitrobenzene	EPA 504.1	98 %	Acceptable range: 70-130 %						
Organohalide Pesticides and PCBs by GC-ECD									
Aldrin	EPA 505	ND	0.075	ug/L	1	AGC1912	03/31/23	04/01/23	
Chlordane (Technical)	EPA 505	ND	0.10	ug/L	1	AGC1912	03/31/23	04/01/23	
Dieldrin	EPA 505	ND	0.020	ug/L	1	AGC1912	03/31/23	04/01/23	
Endrin	EPA 505	ND	0.10	ug/L	1	AGC1912	03/31/23	04/01/23	
Heptachlor	EPA 505	ND	0.010	ug/L	1	AGC1912	03/31/23	04/01/23	
Heptachlor Epoxide	EPA 505	ND	0.010	ug/L	1	AGC1912	03/31/23	04/01/23	
Hexachlorobenzene	EPA 505	ND	0.50	ug/L	1	AGC1912	03/31/23	04/01/23	
Hexachlorocyclopentadiene	EPA 505	ND	1.0	ug/L	1	AGC1912	03/31/23	04/01/23	
Lindane	EPA 505	ND	0.20	ug/L	1	AGC1912	03/31/23	04/01/23	
Methoxychlor	EPA 505	ND	10	ug/L	1	AGC1912	03/31/23	04/01/23	
PCB Aroclor Screen	EPA 505	ND	0.50	ug/L	1	AGC1912	03/31/23	04/01/23	
Toxaphene	EPA 505	ND	1.0	ug/L	1	AGC1912	03/31/23	04/01/23	
Surrogate: 1-Br-2-Nitrobenzene	EPA 505	98 %	Acceptable range: 70-130 %						
Chlorinated Acid Herbicides by GC-ECD									
2,4,5-T	EPA 515.4	ND	1.0	ug/L	1	AGD0020	04/03/23	04/05/23	
2,4,5-TP (Silvex)	EPA 515.4	ND	1.0	ug/L	1	AGD0020	04/03/23	04/05/23	
2,4-D	EPA 515.4	ND	10	ug/L	1	AGD0020	04/03/23	04/05/23	
Bentazon	EPA 515.4	ND	2.0	ug/L	1	AGD0020	04/03/23	04/05/23	
Dalapon	EPA 515.4	ND	10	ug/L	1	AGD0020	04/03/23	04/05/23	
Dicamba	EPA 515.4	ND	1.5	ug/L	1	AGD0020	04/03/23	04/05/23	
Dinoseb	EPA 515.4	ND	2.0	ug/L	1	AGD0020	04/03/23	04/05/23	
Pentachlorophenol	EPA 515.4	ND	0.20	ug/L	1	AGD0020	04/03/23	04/05/23	
Picloram	EPA 515.4	ND	1.0	ug/L	1	AGD0020	04/03/23	04/05/23	
Surrogate: DCPAA	EPA 515.4	107 %	Acceptable range: 70-130 %						
Volatile Organics (SDWA Regulated) by GC-MS									
1,1,1-Trichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1,2,2-Tetrachloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1,2-Trichloro-1,2,2-trifluoroethane	EPA 524.2	ND	10	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1,2-Trichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1-Dichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,1-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2,4-Trichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2-Dichloroethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,2-Dichloropropane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
1,4-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AGC3527 FINAL 04052023 1826



AGC3527

General EDT
Sunny Mesa WS

Certificate of Analysis

Sample ID: AGC3527-02
 Sampled By: Rafael Farfan
 Sample Description: 19 Bay Farms Rd // 230329_36-02

Sample Date - Time: 03/29/2023 - 13:30
 Matrix: Drinking Water
 Sample Type: Grab

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Volatile Organics (SDWA Regulated) by GC-MS									
Benzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Carbon Tetrachloride	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Chlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
cis-1,2-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
cis-1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Dichloromethane	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Ethylbenzene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
m,p-Xylenes	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Methyl-t-butyl ether	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
o-Xylene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Styrene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Tetrachloroethene (PCE)	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Toluene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
trans-1,2-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
trans-1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Trichloroethene (TCE)	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Trichlorofluoromethane	EPA 524.2	ND	5.0	ug/L	1	AGD0112	04/04/23	04/04/23	
Vinyl Chloride	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Total 1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Total Xylenes	EPA 524.2	ND	0.50	ug/L	1	AGD0112	04/04/23	04/04/23	
Surrogate: 1,2-Dichlorobenzene-d4	EPA 524.2	99 %							Acceptable range: 70-130 %
Surrogate: Bromofluorobenzene	EPA 524.2	90 %							Acceptable range: 70-130 %
Semi-Volatile Organics by GC-MS									
Alachlor	EPA 525.3	ND	1.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Atrazine	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Benzo(a)pyrene	EPA 525.3	ND	0.10	ug/L	1	AGC1904	03/30/23	04/03/23	
Bis(2-ethylhexyl) adipate	EPA 525.3	ND	3.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Bis(2-ethylhexyl) phthalate	EPA 525.3	ND	3.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Bromacil	EPA 525.3	ND	10	ug/L	1	AGC1904	03/30/23	04/03/23	
Butachlor	EPA 525.3	ND	0.38	ug/L	1	AGC1904	03/30/23	04/03/23	
Diazinon	EPA 525.3	ND	0.25	ug/L	1	AGC1904	03/30/23	04/03/23	
Dimethoate	EPA 525.3	ND	10	ug/L	1	AGC1904	03/30/23	04/03/23	
Metolachlor	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Metribuzin	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Molinate	EPA 525.3	ND	2.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Propachlor	EPA 525.3	ND	0.50	ug/L	1	AGC1904	03/30/23	04/03/23	
Simazine	EPA 525.3	ND	1.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Thiobencarb	EPA 525.3	ND	1.0	ug/L	1	AGC1904	03/30/23	04/03/23	
Surrogate: 1,3-Dimethyl-2-nitrobenzene	EPA 525.3	92 %							Acceptable range: 70-130 %
Surrogate: Benzo(a)pyrene-d12	EPA 525.3	95 %							Acceptable range: 70-130 %
Surrogate: Triphenyl Phosphate	EPA 525.3	119 %							Acceptable range: 70-130 %

Carbamates by HPLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AGC3527 FINAL 04052023 1826



AGC3527

General EDT
Sunny Mesa WS

Certificate of Analysis

Sample ID: AGC3527-02
 Sampled By: Rafael Farfan
 Sample Description: 19 Bay Farms Rd // 230329_36-02

Sample Date - Time: 03/29/2023 - 13:30
 Matrix: Drinking Water
 Sample Type: Grab

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>Carbamates by HPLC</u>									
3-Hydroxycarbofuran	EPA 531.1	ND	3.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Aldicarb	EPA 531.1	ND	3.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Aldicarb Sulfone	EPA 531.1	ND	2.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Aldicarb Sulfoxide	EPA 531.1	ND	3.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Carbaryl	EPA 531.1	ND	5.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Carbofuran	EPA 531.1	ND	5.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Methomyl	EPA 531.1	ND	2.0	ug/L	1	AGD0090	04/04/23	04/05/23	
Oxamyl	EPA 531.1	ND	20	ug/L	1	AGD0090	04/04/23	04/05/23	
<u>Glyphosate by HPLC</u>									
Glyphosate	EPA 547	ND	25	ug/L	1	AGC1851	03/30/23	03/30/23	
Surrogate: AMPA	EPA 547	96 %	Acceptable range: 70-130 %						
<u>Endothall by GC-MS</u>									
Endothall	EPA 548.1	ND	45	ug/L	1	AGC1969	03/31/23	04/03/23	
<u>Diquat by HPLC</u>									
Diquat	EPA 549.2	ND	4.0	ug/L	1	AGD0010	04/02/23	04/04/23	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.